

Connection (*00)

Note these points in the following Katherm QL wiring diagrams:

- ▶ Comply with the details on cable types and cabling with due consideration of VDE 0100.
- ▶ Without *: NYM-J. The requisite number of wires, including protective earth, is stated on the cable. Cross-sections are not stated, as the cable length is involved in the calculation of the cross-section.
- ▶ With *: J-Y(ST)Y 0.8mm. Lay separately from power lines. If other types of cables are used, they must be at least equivalent.
- ▶ The electrical data of the thermoelectric actuator needs to be considered when rating the mains power supply and fuses on site.





